

DELTA PLUS GROUP declares that this product complies with the following regulations :

Identification of the PPE object of the declaration :

VISORFLASH - VISOR FLASH ArcFit 14

Designation :

POLYCARBONATE INJECTED VISOR

Colour :

Green

Size :

No size



Specifications :

Polycarbonate injected visor, against electric arc and thermal risk. Green shade for better transmission of light.

The PPE is also identifiable by the following means :

- The product picture
- Each PPE wears the name indicated on this declaration of conformity.
- Each PPE wears the bar code indicated in the annex to this declaration of conformity
- Each PPE wears a batch number. For any further information, just give it to us. Our organization, based on this batch number, allows us to ensure the traceability of the PPE.

EU DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The object of the declaration identified above is in conformity with the relevant Union harmonisation legislation:

EU 2016/425 Regulation, with its requirements and with the harmonised standards:



REGULATION (EU) 2016/425

EN166:2001 Personal eye-protection - Specifications

1FT 8: Oculars

EN170:2002 Ultraviolet filters

UV 2C-1.7: echelon

GS-ET 29:2011-05 Additional requirements electric arc protection.

VISOR-U 8-2-1: Oculars

VISOR-HOLDER 8-1-1: Oculars

VISOR-U:2 ,VISOR-HOLDER:1: Class

1: Light transmittance class = Class 1 : (50% ≤ VLT(D65) < 75%) / Class 0 : (VLT(D65) ≥ 75%).



DECLARATION OF CONFORMITY

0196 - DIN CERTCO GESSELLSCHAFT (FÜR KONFORMITÄTBEWERTUNG MBH - ALBOINSTRASSE 56 12103 BERLIN GERMANY) :

Notified body which performed the EU Type- examination (module B) and issued EU type-examination certificate: C5655DELTA R1 (VISOR HOLDER + VISOR FLASH)

0196 - DIN CERTCO GESSELLSCHAFT (FÜR KONFORMITÄTBEWERTUNG MBH - ALBOINSTRASSE 56 12103 BERLIN GERMANY) :

Notified body which performed the EU Type- examination (module B) and issued EU type-examination certificate: C5734DELTA R1 (VISOR FLASH VISOR U)

The PPE is subject to the conformity assessment procedure to type based on internal production control plus supervised product checks at random intervals (Module C2) under surveillance of the notified body : 0196 - DIN CERTCO GESSELLSCHAFT (FÜR KONFORMITÄTBEWERTUNG MBH - ALBOINSTRASSE 56 12103 BERLIN GERMANY)

USA STANDARDS



ASTM-F-2178-12 Standard Test Method for Determining the Arc Rating and Standard Specification for Face Protective Products.

14 cal/cm²: Protection value (ATPV)

1+ 2: Category



ANSI Z87.1-2010 American National Standards Institute - Occupational and Educational Personal Eye and Face Protection Devices

Z87+ U6 L1.7: Impact resistance

Apt, 25/04/2020

Signed for and on behalf of DELTA PLUS GROUP :
David GUIHO
Marketing director



ANNEX:

References			
References	Bar code	COLOUR	SIZE
VISORF14	3295249215248	Green	No size